Pool Work Final Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
P-Trap	2009 IPC Carrollton Policy	802.1.4 802.2.1
GFCI for pool lights	2011 NEC	680
GFCI location & testing	2011 NEC	680
Grounding terminations	2011 NEC	680
Fence enclosure, gates and latches	2009 IRC	AG105.2 AG105.2.4
Backflow protection	2009 IPC	608
Backwash/drain pipe	Carrollton Policy	
Any gas line related items Lo pressure 3 lbs on 6 lb visibly certifiable diaphragm gauge High or med. 60 lbs on 100 lb visibly certifiable diaphragm gauge	2009 IRC 2009 IFGC	App. G
Pool heaters ON-OFF switch	2009 IECC	504.3.1
Pool cover for heated pools	2009 IECC	504.3.2
Pool time clocks setting	2009 IECC	504.3.3
Drainage	CZO 2009 IRC	Ord. 1964 R401.3
Entrapment protection/svrs system in place	2009 IRC	Appendix G AG 106