Pool Work Final Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
P-Trap	2012 IPC	802.1.4 802.2.1
	TIM	
GFCI for pool lights	2011 NEC	680
GFCI location & testing	2011 NEC	680
Grounding terminations	2011 NEC	680
Fence enclosure, gates and latches	2012 IRC	AG105.2 AG105.2.4
Backflow protection	2012 IPC	608
Backwash/drain pipe	TIM	
Any gas line related items Lo pressure 3 lbs on 6 lb visibly certifiable diaphragm gauge High or med. 60 lbs on 100 lb visibly certifiable	2012 IRC 2012 IFGC	App. G
diaphragm gauge		
Pool heaters ON-OFF switch	2012 IECC	504.3.1
Pool cover for heated pools	2012 IECC	504.3.2
Pool time clocks setting	2012 IECC	504.3.3
Drainage	CZO 2012 IRC	Ord. 1964 R401.3
Entrapment protection/svrs system in place	2012 IRC	Appendix G AG 106