Electrical/Energy Final Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline

CODE ITEM	CODE	SECTION
Covers, outlets, and fixtures installed	2011 NEC	314.25
Tamper resistant receptacles	2011 NEC	406.11
AFCI (arc fault circuit interrupter) location/testing	2011 NEC	210.12
GFCI locations/testing	2011 NEC	210.8
Luminaire (light fixture) requirements	2011 NEC	410
Appliance installation	2011 NEC	422
Kitchen requirements–disposal cord, cook top flex strap Equipment tie in	2011 NEC	220.55
Smoke alarms in place and working	2012 IRC	R314
Jacuzzi requirements–tub grounded/bonded, dedicated circuit & accessibility	2011 NEC	680.71 - 680.74
Protection of wiring in attics/other attic requirements Service light and outlet, air handler disconnect & attic fan controls	2011 NEC	320.23 210.70 210.63
Electrical panel installation, identification, circuit labels (specific not general), breaker amperage consistent with conductor sizing , i.e. (no #14 romex on 20 amp breaker) Unused openings filled. Panel service conductor sizing	2011 NEC	210.19 215 310.16 408.4 408.7 408.58
Heating and air conditioning circuits (manufactures recommendations)	2011 NEC	440.24 422.12
Outdoor requirements–weather resistant outlets, in use covers	2011 NEC	406.8
Lighting of all egress doors to outside	2011 NEC	210.70
A/C disconnects labeled (if more than one)	2011 NEC	110.22

Electrical/Energy Final Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline

CODE ITEM	CODE	SECTION
Outdoor service outlet for a/c unit	**2011 NEC**	**210.63**
Intersystem bonding terminations	**2011 NEC**	**250.94**