

Establishment: _____

Owner: _____

Address: _____

Date: _____

Inspection Type: 1-Routine 2-Complaint 3-Follow-up

Permit Number: _____ Type: Pool Spa Wade IWFF Public Semi-Public Permit Displayed: Y N / Delivered

Trained Pool Operator: Yes No **Certificate displayed:** Yes No **Follow up inspection required:** Yes No

“X” indicates an alleged deficiency “COS” indicates corrected on site *Items in italics apply to post-10/01/99 pools and spas*

Swimming Pool/Wade Pool	Specific Safety Features – Safety Equipment
1. Chlorine (1-8 ppm) Bromine (2.5-12 ppm)	60. Min 12' non-conductive pole within 20' of pool.
2. pH (7.0 - 7.8)	61. USCG ring buoy w/ throw rope within 20' of pool
3. Cyanuric acid (100 ppm or less)	62. Emergency phone w/in 200' & not answered by onsite office.
4. Deck & sidewall depth markers permanent with 4" numbers.	63. Emergency phone functioning.
5. Markers at max. & min. depth, breakpoint & 2' depth intervals.	Public Pools / Spas
6. Minimum 2 entry exits.	64. Operator license(s) current and available.
<i>7. Depth markers no more than 25 feet apart.</i>	65. Water tested every 2 hours pool / spa is in use (see log).
<i>8. Depth markers – feet and / or inches 4" letters.</i>	66. Rope and float line at shallow to deep transition.
<i>9. Wade pool 15 feet from shallow / 35 feet from deep water areas</i>	67. Dressing / sanitary facilities provided.
<i>10. Wade pool fenced separately from pool / spa.</i>	Lifeguard / Second Responder
<i>11. Wade pool w/ independent circulatory / sanitization system.</i>	68. Lifeguard(s) provided as required (Class A & B/slide/diving board).
Spa	69. Current certification(s) available.
12. Chlorine (2-8 ppm) Bromine (4.5-12 ppm)	70. Second responder on duty.
13. pH (7.0 – 7.8)	71. Sufficient number of rescue tubes provided.
14. Cyanuric acid (100 ppm or less)	72. Backboard with 3 tie-down straps & head immobilizer.
15. Temperature 104°F or less / Spa thermometer available to users.	73. First aid kit with anti-disease transmission capabilities.
16. Emergency shutoff in sight & minimum 5 ft. away.	74. Sufficient in-service training provided (60 minutes / week).
17. Minimum 2 permanent deck depth markers with 4" numbers.	Diving Facilities
<i>18. 15 min timer-switch minimum 5 feet away from spa.</i>	75. Distance between multiple boards minimum 10 feet
Suction Outlets (Main Drains)	76. Lifeguard chair(s) at least 4 feet above deck to view diving area.
19. Suction outlet cover(s) / grate(s) intact and in place.	<i>77. Boards / platforms ½ - 1 M with single guard & handrails.</i>
20. Single suction outlet-SVRD or AVS installed.	<i>78. Boards / platforms over 1 M with 2 / dual guard & handrails.</i>
21. No check valve(s) down-stream of pump.	<i>79. Diving board(s) properly labeled.</i>
22. Equalizer outlet(s) with approved cover or sealed.	Bathroom & Sanitary Facilities
23. Suction outlet VGBA / ASME/ANSI compliant.	80. Facilities clean and sanitary.
<i>24. Dual main drains.</i>	81. Mirror shatter resistant & soap dispenser metal or plastic.
Mechanical	82. Toilet paper & holder provided.
25. Pump functioning.	83. Single use towels or hand dryer provided.
26. Plumbing in good repair	84. Covered waste receptacles.
27. Pump vacuum/inlet/outlet gauges & flowmeter.	<i>85. Floor slip resistant & sloped to floor drains.</i>
28. Heater over 200,000 BTU with TDLR certificate.	<i>86. Private gender specific facilities.</i>
29. Exposed piping labeled to identify function & flow direction.	Glass Containers and Food
30. Strainer on pump	87. Glass containers in pool / spa yard.
Operation, Water Quality & Structural Design	88. Trash containers provided.
31. DPD test kit.	Semi-Public Pools and Spas Fencing (Not Apartments)
32. Automatic chlorinator installed and operational.	89. Minimum 48-inch height.
33. No algae.	90. Gate(s) / door(s) self-closing and self-latching.
34. Water clear – deepest point of pool / spa clearly visible.	91. Gate(s) / door(s) not propped open.
35. Skimmer basket not used to dispense sanitizer.	92. Openings in or under fence do not allow passage of 4" sphere.
36. Skimmer cover securely in place.	93. No structures within 36" allowing fence to be scaled.
37. Pool / spa bottom and sides light color or white.	94. Opening hardware min. 42" above ground.
Electrical	<i>95. Post 10/01/99 no chain link fence after 9/1/2004.</i>
38. Lights in pool / spa equipped with GFCI(s). Also yard & bathhouse	<i>96. Post-10/01/99 gate(s) / door(s) open outward.</i>
39. Pump(s) grounded and bonded.	<i>97. Post-10/01/99 No building door opening directly into pool yard or spa yard that opens outside enclosure.</i>
40. Service electrical disconnect w/in sight of pool / spa equipment.	Public Pools and Spas Fencing
Fill Water/Drinking Water	98. Minimum fence height 6 feet.
41. Fill water potable supply.	99. Fence designed to be difficult to climb.
42. Water distribution system protected against backflow.	100. Openings in or under fence do not allow passage of 4" sphere.
43. Over-the-rim fill spout with secure soft pliable end.	101. Building door does not open outside pool/spa enclosure.
44. Drinking water available.	102. Gate(s) / Door(s) continuously & directly supervised or locked.
Specific Safety Features – No Diving Markers & Transition Line	Apartment Semi-Public Pools and Spas Fencing (HSC 757)
45. Min. 2-4" “NO DIVING” letters & symbol no more than 25' apart.	103. Minimum 48-inch height
46. 4" x 4" line on bottom at transition from shallow to deep.	104. Gate(s) / door(s) self-closing and self-latching.
Specific Safety Features - Signage	105. Gate(s) / door(s) not propped open.
47. Sign(s) visible to pool / spa user in all areas of pool / spa yard.	106. Openings in chain link fabric less than 2-1/4".
48. NO DIVING - 4" LETTERS and symbol.	107. Latch must either be outside & minimum 60" above the ground; or
49. WARNING-NO LIFEGUARD ON DUTY - 4" letters.	108. Latch must be inside only & 3" below top of gate / door; and
50. Maximum user load – 2" letter.	109. No openings exceeding 1/2" w/in 18" of latch.
51. In case of emergency, call 911	110. Latch min. 42" above ground & opens w/ key, card, or comb.
52. DO NOT USE SPA, IF WATER TEMP IS ABOVE 104°F OR 40°C – 2" letters	111. Horizontals at least 36" apart w/gaps less than 4".
53. Non-Service Animals Prohibited – 2"	<i>112. >1/01/1994 horizontals < 45" apart and no gaps > 1-3/4"; or</i>
54. Changing Diapers Within 6 Feet Of The Water Is Prohibited -2"	<i>113. After 1/01/1994 horizontals min. 45" apart/gaps less than 4".</i>
55. Do Not Drink Water From Water Feature – 2"	<i>114. No chain link after 01/01/94.</i>
56. Use When Ill With A Contagious Disease Is Prohibited – 2"	<i>115. Windows in wall(s) permanently closed after 01/01/1994.</i>
57. Use When Ill With Diarrhea Or Vomiting Is Prohibited – 2"	<i>116. After 1/01/1994 gate(s) / door(s) open outward.</i>
58. Phone location sign visible in pool / spa yard	<i>117. No fence cutouts w/gaps greater than 1-3/4" after 01/01/94.</i>
59. Closed Until Further Notice – 4" and locked when pool closed	Other
	118. Site Operator name & number posted – 2"
	119. Pool maintenance & operating records on site

Pool enclosures not subject to HSC 757 include: hotels, youth camps, RV parks, Class B, child care, schools, etc.

Comments: _____

Inspected by (signature):	Representative (signature):
Printed Name:	Printed Name:
Date:	Date: