



GUIDELINES FOR VIRTUAL INSPECTIONS FOR HVAC

The following pictures must be included if applicable to work:

1. Vent pipe from draft hood to ceiling or roof penetration
2. Air supply/make up air
3. Condensate; secondary pan, drain piping
4. Support/Strapping for unit and ductwork
5. Sealed duct and unit joints
6. Carbon monoxide detectors
7. Gas piping
8. Exterior line set insulation (UV & damage protection)
9. Locking caps on condenser
10. Disconnect and electrical panel (with proper labeling and designation if more than one unit)
11. Manufacturer's Name plate with listings
12. A general location picture of the HVAC components