

## 2021 IMC AMENDMENTS – CHAPTER 1

**\*\*Section 101.1; amend to read as follows:**

**101.1 Title.** These regulations shall be known as the *Mechanical Code* of the City of Carrollton, hereinafter referred to as “this code.”

**\*\*\*Section 102.8; amend to read as follows:**

**102.8 Referenced Codes and Standards.** The codes and standards referenced herein shall be those that are listed in Chapter 15 and such codes, when specifically adopted, and standards shall be considered part of the requirements of this code to the prescribed extent of each such reference. Where differences occur between provisions of this code and the referenced standards, the provisions of this code shall apply. Whenever amendments have been adopted to the referenced codes and standards, each reference to said code and standard shall be considered to reference the adopted amendments. Any reference to NFPA 70 shall mean the National Electrical Code as adopted.

**\*\*Sections 103 and 103.1; amend to read as follows:**

### SECTION 103 BUILDING INSPECTION

**103.1 Creation of agency.** The Building Inspection Division of the Development Services Department is hereby created and the official in charge thereof shall be known as the *building official*.  
*[Remainder unchanged]*

## 2021 IMC AMENDMENTS – CHAPTER 3

**\*\*Section 306.5; amend to read as follows:**

**306.5 Equipment and Appliances on Roofs or Elevated Structures.** Where *equipment* requiring *access* or appliances are located on an elevated structure or the roof of a building such that personnel will have to climb higher than 16 feet (4877 mm) above grade to access, an interior or exterior means of access shall be provided. Exterior ladders providing roof *access* need not extend closer than 12 feet (2438 mm) to the finish grade or floor level below and shall extend to the *equipment* and appliances' level service space. Such *access* shall not require climbing... [*remainder of text unchanged*].

**\*\*Section 306.5.1; amend to read as follows:**

**306.5.1 Sloped Roofs.** Where appliances, *equipment*, fans or other components that require service are installed on a roof having a slope of three units vertical in 12 units horizontal (25-percent slope) or greater and having an edge more than 30 inches (762 mm) above grade at such edge, a catwalk at least 16 inches in width with substantial cleats spaced not more than 16 inches apart shall be provided from the roof *access* to a level platform at the appliance. The level platform shall be provided on each side of the appliance to which *access* is required for service, repair or maintenance. The platform shall be not less than ... [*Remainder of text unchanged*].

## 2021 IMC AMENDMENTS – CHAPTER 5

**\*\*Section 501.3; add Exception 4 to read as follows:**

**501.3 Exhaust Discharge.** [*Exiting text to remain*].

4. Toilet room exhaust ducts may terminate in a warehouse or shop area when infiltration of outside air is present.

**END OF IMC AMENDMENTS**