

## Plumbing Work Final Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline.

CODE ITEM	CODE	SECTION
Accessibility of valve for outside water supply	2021 IPC	606.3
Clean-outs for sewer lines to grade	2021 IPC	708
Backflow preventions	2021 IPC	608
Water heater clearances	2021 IPC	502.5
Pressure relief valves	2021 IPC	504
Gas pipes shut off valves	2021 IFGC	409
Gas connectors locations, length, materials	2021 IFGC	411
Water heater vent termination	2021 IFGC	503
Plumbing fixtures in place, secure	2021 IPC	405
Waste pipe vent termination	2021 IPC	904.3
Thermal expansion device	2021 IPC	607.3
Fixture traps	2021 IPC	1002