

Paving Inspection Checklist

This checklist is not to be construed as all-inclusive; it is only to be used as a guideline..

CODE ITEM	CODE	SECTION
Soil engineer and lab	GDS (Paving)	2.A.1
Emulsified asphalt	GDS (Paving)	2.D.8
Density 95% of maximum dry density Proctor: ASTM D698	GDS (Testing)	2.O.General Notes
Concrete mixtures and testing	GDS (Paving)	2.D
Concrete thickness	GDS (Paving)	P-20
Reinforcing Fire lanes #3 bars @ 18" o. c.	GDS (Paving)	P-20
Fire lanes 24 feet clear width Marking	GDS (Paving)	P-20
Parking areas	GDS (Paving)	2.P.9
Dumpster pads	GDS (Paving)	2.P.9